



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

KIMBERLY K. HOOD
Executive Director

Division of Facilities Construction and Management

DAVID G. BUXTON
Director

ADDENDUM #5

Date: 18 April 2008

To: Design/Build Teams

From: Matthias Mueller, Project Manager

Reference: Southern Utah University
Student Life Center – Design/Build Stage II
DFCM Project No. 07032730

Subject: **Addendum No. 5**

Pages	<u>Addendum</u>	<u>1</u>	<u>page</u>
	Total	1	page

Note: *This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum.*

While we contend that SB220 should only be potentially applicable to a contract issued after the effective date of said bill, this is to clarify that for purposes of this contract, regardless of the execution or effective dates of this contract, the status of Utah Law and remedies available to the State of Utah and DFCM, as it relates to any matter referred to or affected by said SB220, shall be the Utah law in effect at the time of the issuance of this Addendum.

5.1 SCHEDULE CHANGES – There are no changes to the Project Schedule per this addendum.

5.2 GENERAL ITEMS

There is no performance specification for the fire sprinkler system. Provide a Sprinkler system as called out on p. 65 of the Program under “Fire Suppression”, but change the text in note #4 from “fully recessed” to “concealed”.

End of Addendum #5